

SAFETY INSPECTION REQUIREMENTS

Updated May 17, 2010

INSPECTION	SBVC					CHC					DISTRICT					CODE REFERENCE
	Monthly	Quarterly	Annual	Bi-Annual	Five Years	Monthly	Quarterly	Annual	Bi-Annual	Five Years	Monthly	Quarterly	Annual	Bi-Annual	Five Years	
• Emergency Eye Washes & Showers	x					x					na					T8CCR5162
• Fire Alarms			x	x				x					x			NFPA
• Fire Extinguishers: Visual Inspection	x					x					x					T8CCR6151
• Fire Extinguisher Service & Recharge			x					x					x			
• Fire Sprinklers: Main Drain Flow Test, Sprinkler/Riser Inspection, Kitchen Fire Suppression	x		x	x	x			x					na na na	na		T8CCR6170 NFPA
• Fire Sprinklers: Inspector's Test Valve									x							T8CCR6170
• Fire Hydrants			x					x					na			NFPA
• Backflow Testing & Certification			x					x					x			
• Mechanical Ventilation Systems: Lab Fume, Hoods, Dust Collection System, Kitchen Exhaust Hoods	x		x					x					na			T8CCR5143
• Elevators: Service (lights, phones alarms etc)			x			x					na					
State Inspection								x					na			
• Gasoline Tank-Vapor Recovery, Dynamic back Pressure test, hoses & Pump	na	na	na	na	Na			x					na			Required by SCAQMD
• Pressure Vessels			x					x					na			
• Boilers: Flue gas Analysis			x				x					na				
Combustion Source Testing			x							x					na	
• Refrigerant Monitors			x					x					na			
• AED Equipment				x				x					na			
• General facility Self Inspection: Safety Signage, Electrical Panel Access, Raised Sidewalks/Path of Travel, Machinery-Guards, Electrical Cords, Storage Areas, Ladders, First Aid Kits, Hazardous Materials Storage			x	x				x					x			

